



January 13, 2024

To,
The General Manager
BSE Limited
Phiroze Jeejeebhoy Towers
Dalal Street
Mumbai 400 001

To,
Asst. Vice President,
National Stock Exchange of India Ltd.
Exchange Plaza, C-1, Block G, Bandra
Kurla Complex, Bandra (E),
Mumbai 400 051

BSE Srip code: 516082
NSE symbol: NRAIL

Sub:- Intimation for Turbine Breakdown at the Writing Printing Unit (Unit V) under Regulation 30 of LODR

Dear Sir/Madam,

Pursuant to the Regulation 30 of the SEBI (Listing Obligations and Disclosure Requirements) Regulations, 2015, it is hereby informed that the 12th stage rotor blade of 18 MW Siemens turbine at Unit V is found damaged and is being sent for repair. Hence, the writing printing unit will remain shut till it is re-commissioned. We have lodged machinery breakdown claim under IAR policy for the same.

Request you to kindly take the same on record.

Thanking you,

Yours faithfully,

For N R Agarwal Industries Limited,

Pooja Daftary
Company Secretary & Compliance Officer